



**Minnehaha County Parking Lot Improvements
Parking Lot H
405 North Minnesota Avenue
Minnehaha County**

CONTRACTOR'S BID DATE: Wednesday, April 4, 2018, 10:15 A.M.
Bids Opened/Read at 10:30 A.M.

PLACE FOR CONTRACTOR'S
TO SUBMIT BIDS: Minnehaha County Auditor's Office
415 North Dakota Avenue
Sioux Falls, SD 57104

ADDENDUM NO. 1
March 21, 2018

TO ALL PLANHOLDERS:

The following changes, additions, and/or deletions are hereby made a part of the contract documents for the above-referenced project, as fully and completely as if the same were fully set forth therein:

Bid Date Clarification

Plans provided via the various exchanges incorrectly listed the project bid date as March 28, 2018.

The project bid date shall be on April 4 as noted above.

All bidders shall acknowledge receipt and acceptance of ADDENDUM NO. 1 by signing the space provided on the Proposal Form.

END OF ADDENDUM NO. 1

**Minnehaha County Parking Lot Improvements
Parking Lot H
405 North Minnesota Avenue
Minnehaha County**

CONTRACTOR'S BID DATE: Wednesday, April 4, 2018, 10:15 A.M.
Bids Opened/Read at 10:30 A.M.

PLACE FOR CONTRACTOR'S
TO SUBMIT BIDS: Minnehaha County Auditor's Office
415 North Dakota Avenue
Sioux Falls, SD 57104

ADDENDUM NO. 2
April 2, 2018

TO ALL PLANHOLDERS:

The following changes, additions, and/or deletions are hereby made a part of the contract documents for the above-referenced project, as fully and completely as if the same were fully set forth therein:

Site Removals Clarification

Some site items noted for demolition have been removed by the owner. THE CONTRACTOR IS STRONGLY ENCOURAGED TO VISIT THE SITE PRIOR TO BIDDING. In addition, the water and sanitary services have been terminated to the back of sidewalk. Removals and further discontinuation of the services within Minnesota Avenue are required as shown on the plans. The gas service has been terminated as required by the gas company.

Hot Box Enclosure Clarification

The plans show a hot box enclosure to be installed on the south west portion of the site over the 1" domestic service. No further specifications have been given for the hot box in the plans. The following is being specified for the hotbox.

The hot box enclosure shall be a heated, insulated flip top fiberglass type enclosure with dimensions of 21W X 33L X 25H such as the "Hubbell HB1.5 Flip Top – Insulated – 21W X 33L X 25H (Heated)" hot box enclosure or an approved equivalent by the Engineer.

Construction Staking

The staking for the project will be provided by the owner. Any re-staking will be at the Contractor's expense.

All bidders shall acknowledge receipt and acceptance of ADDENDUM NO. 2 by signing the space provided on the Proposal Form.

END OF ADDENDUM NO. 2