

## FACT OF ADOPTION

The Minnehaha County Board of Commissioners adopted Ordinance MC20-05-09 on June 16, 2009. This ordinance amended Ordinance MC20-92, the On-Site Wastewater Treatment Treatment Ordinance by

Amending the permit fee portion of Section 2.01. to read as follows:

Routine maintenance and repair	\$75.00
Installation of a holding tank only	\$100.00
Extension of existing drainfield	\$150.00
New or replacement system	\$150.00
Engineered system	\$175.00

And Amending Section 7.02 to read as follows:

Section 7.02. Rapidly Permeable Soils: For soils with a percolation rate faster than 6 minutes per inch, a soil absorption system may be used only if a soil liner system (Figure 7-1) is constructed to place a minimum of 12 inches of a soil having a percolation rate between 16 and 24 minutes per inch between the bottom of the rock layer and the high percolation rate soil. The system shall be sized using the soil sizing factor for sandy loam soil 1.67 square feet per gallon per day.

Sue Roust, County Auditor

Published twice at the total approximate cost of \$\_\_\_\_\_.

**PUBLISH: Argus Leader – June 22 & 29, 2009**  
**Dell Rapids Tribune – June 24 & July 1, 2009**  
**Brandon Valley Weekly – June 24 & July 1, 2009**